

CUSTOMER GENERATION PARALLEL SOURCE - 25kW AND LESS

This is an example of using the customer generation as a parallel source. This installation must comply with all NEC and IEEE standards for utility-customer interconnections, all other applicable code requirements, and must be approved by the Electric Utility. Approval by the Electric Utility means that the Manual Disconnect works and has been installed at the appropriate location. It is the customer's responsibility to assure the installation meets all code requirements and is properly maintained.

